

Site YOUR SITE

Contract No **0126**

Sample Sample 1

Client Your Client

Engineer Your Engineer

Sample Type B

Particle Size	% Passing
125.0 mm	100
90.0 mm	100
63.0 mm	100
31.5 mm	99
16.0 mm	70
8.00 mm	34
4.00 mm	22
2.00 mm	7
1.00 mm	6
500 µm	5
250 µm	4
125 µm	2
63 µm	1


Reception date
06/10/2011

Name of Source
Your Source

Location of Source
Your Location

Non Engineering Description
MADE GROUND: brown sandy gravel with fragments of brick

Notes
Sample meets the grading requirements for SHW series 800 Type 1 Specification



Originator	Checked & Approved
SG	<i>[Signature]</i> 23/11/2011

PARTICLE SIZE DISTRIBUTION
BS EN 933-1:1997 Wet Sieving

